

related test method	EN 1363-1: 1999 Fire resistance – Part 1: General requirements
subject	Content of statements of 'Field of direct application' to be given in test reports
reference of original query	TC2 N284rev2 Helpdesk 2001-08

Problem

EN 1363-1 § 12.1 'Test Report' states under v) that "The field of direct application of the results for the specimen being evaluated" shall be given in the test report.

In practice a test report should only contain the results from the actual test. Additionally, according to the European System statements on direct and extended application (not necessarily produced by the test laboratory) belong in the classification report.

Additionally, it is not clear if, according to §12.1 v), the test report should include the complete list of parameters for direct application from the actual test standard (stating tested or not tested) or only direct application from the results obtained in the actual test.

Recommendation

EGOLF members shall (until further notice) include Field of Direct Application data in test reports by either:

- incorporating a copy of the full direct application text from the test standard into the test report
- making reference in the test report to the direct application clauses in the test standard.

