

related test method	<b>EN ISO 11925-2: 2000 Ignitability of building products subjected to direct impingement of flame – Part 2: Single-flame source test</b>
subject	<b>Testing to annex A of EN ISO 11925-2 and reporting</b>
reference of original query	TC1 N268 Helpdesk 2004-01

---

**Problem**

EN ISO 11925-2 provides a test procedure (in annex A) which may be used for products which melt and shrink from the flame without being ignited, and this is undertaken if required by the sponsor.

When no remarks are made in the report, it is not clear whether the procedure in Annex A was not required, or not relevant. This may result in problems with classification of the product in certain countries.

**Recommendation**

Annex A can be used for classification for class E as well as classes D to B.

Because the test in annex A is only to be used when required by the sponsor, the following texts may be added to the test report to clarify why testing following Annex A was not performed:

-under p) observations made during the test: as the material did not melt and shrink away from the flame without being ignited, the procedure described in annex A of the standard was not considered appropriate.

or, under general remarks, - the procedure described in annex A was not used as it was not required by the sponsor.

